## **DATA SHEET**

## Single Phase Induction Motor - Squirrel Cage



Customer	:			
Product line	: Ge	neral Single-Phase	Product code :	10796011
Frame Output Poles Frequency Rated voltage Rated current L. R. Amperes LRC No load current Rated speed Slip Rated torque Locked rotor torque Breakdown torque Insulation class Service factor Moment of inertia (J)	: 6 : 60 : 115 : 11. : 66. : 6.0 : 115 : 4.1 : 0.6 : 240 : 220 : B	Hz 5/208-230 V 0/5.80-5.50 A 0/34.8-33.0 A x(Code J) 0/2.85-3.30 A 50 rpm 7 % 31 kgfm ) %	Locked rotor time Temperature rise Duty cycle Ambient temperature Altitude Protection degree Cooling method Mounting Rotation¹ Noise level² Starting method Approx. weight³	: 10s (cold) 6s (hot) : 80 K : Cont.(S1) : -20°C to +40°C : 1000 m.a.s.l. : IP55 : IC411 - TEFC : F-1 : Both (CW and CCW) : 50.0 dB(A) : Direct On Line : 22.7 kg
Output 50°	% 759	% 100%	Foundation loads	
Efficiency (%) 64.			Max. traction	: 33 kgf
Power Factor 0.6	3 0.7	2 0.80	Max. compression	: 56 kgf
Bearing type : 6204 ZZ Sealing : V'Ring Lubrication interval : - Lubricant amount : - Lubricant type : Mo		Non drive end 6203 ZZ V'Ring - - - Mobil Polyrex EM		

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

Notes

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.		Changes Summary	Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	26/10/2024			1/2	


## LOAD PERFORMANCE CURVE

## Single Phase Induction Motor - Squirrel Cage



_	
Customer	
Customer	

Product line : General Single-Phase Product code : 10796011



Performance	:	115/208-230 V 60 Hz	6P				
Rated current LRC Rated torque Locked rotor torq Breakdown torqu Rated speed	: : : : : : : : :	11.0/5.80-5.50 A 6.0 0.631 kgfm 240 % 220 % 1150 rpm		Moment o Duty cycle Insulation Service fa Temperatu	class ctor	: 0.0090 kgm : Cont.(S1) : B : : 80 K	2
Rev.		Changes Summary			Performed	Checked	Date

-		•			
Rev.		Changes Summary	Performed	Checked	Date
Performed by					
Checked by		-		Page	Revision
Date	26/10/2024			2/2	

