DATA SHEET

Single Phase Induction Motor - Squirrel Cage



Customer	:				
Product line	: Fai	rm Duty Single	-Phase	Product code :	12079041
Frame Output Poles Frequency Rated voltage Rated current L. R. Amperes LRC No load current Rated speed Slip Rated torque Locked rotor torque Breakdown torque Insulation class Service factor Moment of inertia (J)		: G56H : 2 HP (1. : 4 : 60 Hz : 115/230 : 21.0/10. : 145/72.5 : 6.9x(Coo : 12.4/6.2 : 1750 rpr : 2.78 % : 0.829 kg : 280 % : 250 % : B : 1.15 : 0.0090 kg	V 5 A 5 A de K) 0 A m	Locked rotor time Temperature rise Duty cycle Ambient temperature Altitude Protection degree Cooling method Mounting Rotation¹ Noise level² Starting method Approx. weight³	: 10s (cold) 6s (hot) : 80 K : Cont.(S1) : -20°C to +40°C : 1000 m.a.s.l. : IP55 : IC411 - TEFC : F-1 : Both (CW and CCW) : 55.0 dB(A) : Direct On Line : 22.7 kg
Output	50%	75%	100%	Foundation loads	
Efficiency (%) Power Factor	74.0 0.60	78.0 0.71	78.1 0.78	Max. traction Max. compression	: 55 kgf : 78 kgf
Bearing type Sealing Lubrication intel Lubricant amou Lubricant type		:	Drive end 6204 ZZ V'Ring - -	Non drive end 6203 ZZ V'Ring - - Mobil Polyrex EM	

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.		Changes Summary	Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	31/01/2024			1/2	


LOAD PERFORMANCE CURVE

Single Phase Induction Motor - Squirrel Cage



Customer	
Cusioniei	_

Product line : Farm Duty Single-Phase Product code : 12079041



Performance		: 115/230 V 60 Hz 4P				
Rated current LRC Rated torque Locked rotor tord Breakdown torqu Rated speed	•	: 21.0/10.5 A : 6.9 : 0.829 kgfm : 280 % : 250 % : 1750 rpm	Moment of Duty cycle Insulation Service fa Temperat	class actor	: 0.0090 kgm : Cont.(S1) : B : 1.15 : 80 K	2
Rev. Changes Summary			Performed	Checked	Date	

Rev.		Changes Summary	Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	31/01/2024			2/2	