DATA SHEET

Three Phase Induction Motor - Squirrel Cage



12.5

Customer :

Product line : NEMA Premium Efficiency Three- Product code : 12707693

Phase

Frame : 254/6T Cooling method : IC411 - TEFC Insulation class : F Mounting : F-1

Duty cycle : Cont.(S1) Rotation¹ : Both (CW and CCW)
Ambient temperature : -20°C to +40°C Starting method : Direct On Line

12.5

Altitude : 1000 m.a.s.l. Approx. weight³ : 81.0 kg
Protection degree : IP55 Moment of inertia (J) : 0.0367 kgm²

15

Protection degree : IP55
Design : B

Output [HP]

a side on [i ii]				1	
Poles		2	2	2	
Frequency [Hz]		60	50	50	
Rated voltage [V]		230/460	190/380	220/415	
Rated current [A]		34.8/17.4	35.4/17.7	32.3/17.1	
L. R. Amperes [A]		237/118	244/122	245/130	
LRC [A]		6.8x(Code G)	6.9x(Code H)	7.6x(Code J)	
No load current [A]		13.0/6.50	13.6/6.80	13.9/7.39	
Rated speed [RPM]		3525	2920	2930	
Slip [%]		2.08	2.67	2.33	
Rated torque [kgfm]		3.09	3.11	3.10	
Locked rotor torque [%]		200	190	210	
Breakdown torque [%]		300	290	330	
Service factor		1.15	1.00	1.00	
Temperature rise		80 K	105 K	105 K	
Locked rotor time		25s (cold) 14s (hot)	0s (cold) 0s (hot)	0s (cold) 0s (hot)	
Noise level ²		75.0 dB(A)	dB(A) 72.0 dB(A)		
	25%	89.2	90.7	90.1	
Efficiency (%)	50%	89.5	90.2	90.0	
	75%	91.0	90.6	90.7	
	100%	91.0	89.8	90.3	
Power Factor	25%	0.47	0.47	0.43	
	50%	0.73	0.74	0.70	
	75%	0.83	0.84	0.81	
	100%	0.87	0.88	0.86	

<u>Drive end</u> <u>Non drive end</u> Foundation loads

Bearing type : 6309 Z C3 6208 Z C3 Max. traction : 120 kgf Sealing : V'Ring Without Max. compression : 201 kgf

Bearing Seal
Lubrication interval : 15797 h 20000 h
Lubricant amount : 13 g 8 g

Lubricant amount : 13 g 8 g Lubricant type : Mobil Polyrex EM

Notes

USABLE @208V 38.5A SF 1.00 SFA 38.5A

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.

(4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

(1) / 11 100 / 10 01 10					
Rev.	Changes Summary		Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	13/05/2022	1		1/4	

LOAD PERFORMANCE CURVE


Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : NEMA Premium Efficiency Three- Product code : 12707693

Phase



Performance	: 230/460 V 60 Hz 2P				
Rated current LRC Rated torque Locked rotor torque Breakdown torque Rated speed	: 34.8/17.4 A : 6.8 : 3.09 kgfm : 200 % : 300 % : 3525 rpm	Moment of inertia (J) Duty cycle Insulation class Service factor Temperature rise Design	: 0.0367 kgm² : Cont.(S1) : F : 1.15 : 80 K : B	: Cont.(S1) : F : 1.15 : 80 K	
Rev.	Changes Summary	Performed	Checked	Date	
Performed by					
Checked by			Page	Revision	

2/4

13/05/2022

Date

LOAD PERFORMANCE CURVE


Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : NEMA Premium Efficiency Three- Product code : 12707693

Phase



Performance	e : 190/380 V 50 Hz 2P					
Rated current		35.4/17.7 A	.4/17.7 A Moment of inertia (J)		: 0.0367 kgm²	
LRC		6.9	Duty cycle		: Cont.(S1)	
Rated torque		: 3.11 kgfm Insulation		class	: F	
Locked rotor torque		190 %	Service factor		: 1.00	
Breakdown torque	:	: 290 % Tem	Temperati	ıre rise	: 105 K	
Rated speed	:	: 2920 rpm			: B	
Rev.		Changes Summary	1	Performed	Checked	Date
Performed by						
Checked by					Page	Revision
Date	13/05/2022				3 / 4	

LOAD PERFORMANCE CURVE

Three Phase Induction Motor - Squirrel Cage



Customer :


Checked by

Date

13/05/2022

Product line : NEMA Premium Efficiency Three- Product code : 12707693

Phase



Performance : 22		: 220/415 V 50 Hz 2	Р			
Rated current LRC Rated torque Locked rotor tord Breakdown torqu Rated speed	•	: 32.3/17.1 A : 7.6 : 3.10 kgfm : 210 % : 330 % : 2930 rpm	Moment of Duty cycles Insulation Service for Temperation Design	n class actor	: 0.0367 kgm ² : Cont.(S1) : F : 1.00 : 105 K : B	
Rev.		Changes Summa	ary	Performed	Checked	Date
Performed by				ı		

Page

4/4

Revision