


125 HP 06 Poles 60 Hz										A
Without vertical jackscrews										
DE roller bearing										
Grease outlet according to IEEE841										
Shaft locking device										
Color RAL 5009										
Painting plan 222E										
Mounting NEMA F-1										
Mounting B3R(D)										



ECM	LOC	SUMMARY OF MODIFICATIONS				HYBRISUSER				00
EXECUTED	HYBRISUSER	THREE PH. MOTOR IEEE 841 W22 NEMA PREM. EFF.					PREVIEW			
CHECKED		FRAME 444/5T IP56 TEFC					WDD	00		
RELEASED							SHEET	/		
REL. DATE										